



OFFICE OF THE Addl. CE (P&W)
SHREE SINGAJI THERMAL POWER PROJECT, M.P.P.G.C.L.
Dongalia, District KHANDWA- 450112 (M.P.)
(An ISO 9001:2015, ISO 14001:2015, ISO 45001:2018 Certified Station)
Email ID- sepnw.sstpp1@gmail.com, CIN: U40109MP2001SGC014882
Official Website: www.mppgcl.mp.gov.in



No. 515-1700/SSTPP/MPPGCL/P&W/ PT-3175/T-2025_MPPGC_416449/783

dtd. 25.04.2025

Tender Schedule

Sub: Procurement of belt for gravimetric Raw Coal feeder (Model: EG-3651) for PH-I & PH-II for SSTPP, MPPGCL, Dongalia

S. No.	Item Description	Proposed Qty	Unit
1.00	Zipped type rubber belt for 36" Raw coal feeder, Belt specifications:- Circumferential length= 5476+-25mm, width- 1168+-4mm, Thickness= 8.9mm +-0.4mm, Top rubber cover-3mm, Bottom rubber cover-2mm, Intergrally moulded side teeth & middle "V" Guide, Belt should be fire resistant confirming to type A2, IS 1891(Part-2) of 1993, Material-Nylon N-66, Carcass N-17 quality, Tensile Strength & elongation of rubber cover should be as per IS 1891(Part-5) of 1993.	14	Nos.
2.00	Endless Belt(Without any joint) for 36" Gravimetric Raw coal feeder, Belt specifications:- Circumferential length= 5476+-25mm, width- 1168+-4mm, Thickness= 8.9mm +-0.4mm, Top rubber cover-3mm, Bottom rubber cover-2mm, Intergrally moulded side teeth & middle "V" Guide, Belt should be fire resistant confirming to type A2, IS 1891(Part-2) of 1993, Material-Nylon N-66, Carcass N-17 quality, Tensile Strength & elongation of rubber cover should be as per IS 1891(Part-5) of 1993.	34	Nos

--SD--

(Sanjeev Saraf)
Superintending Engineer (Purchase)
SSTPP, MPPGCL, Dongalia